

This is Why We Wear Arc Flash Gear

This is UGLY ..... One look at the pictures will make you a believer.

#### Executive Summary

On 03/04/2009 at 08:40 hours an electrical flashover was reported while the contractor was trying to find information regarding 480 V breakers. This resulted in injuring three contractor employees; one with first degree burn and two with 2nd degree burns. All the victims were transported to clinic for first aid treatment and then transported to Care Hospital for further examination and treatment.



