

ASTs are everywhere



BACKUP POWER GENERATION



FUEL DISPENSING



BULK STORAGE



Resources

- SP001 Standard for the Inspection of Aboveground Storage Tanks, STI/SPFA, www.stispfa.org
- R111 Recommended Practice for Storage Tank Maintenance, May 2016, STI/SPFA, www.stispfa.org
- SP031 Standard for Inspection & Repair of Aboveground Steel Tanks, STI/SPFA, www.stispfa.org
- RP 1621 Bulk Liquid Stock Control at Retail Outlets, Appendix D Water Gauging Procedure, American Petroleum Institute (API), www.api.org
- D6469-14 Standard Guide for Microbial Contamination in Fuels and Fuel Systems, American Society for Testing and Materials (ASTM), www.astm.org
- NFPA 30, Flammable and Combustible Liquids Code, 2015 Edition, National Fire Protection Association, www.nfpa.org

Information published herein is provided without representations or warranties by STI/SPFA, express or implied. © STI/SPFA

Money-saving information
about your storage tank system

944 Donata Court
Lake Zurich IL 60047



**Fuel Storage
Tank Owners/Operators:**
INSPECT your tanks
MAINTAIN your tanks
REDUCE your risk

**Inspect and maintain
your fuel storage system**



944 Donata Court
Lake Zurich IL 60047
847-438-8265
info@steeltank.com
©2024 STI/SPFA

Is your storage tank system at risk?

Poor operations and maintenance procedures for monitoring and removing water from storage tank systems can lead to a number of risks, from fuel quality degradation and resulting poor vehicle performance, to microbial contamination and damage to storage and dispensing system equipment. And these risks can affect your profits.


All storage tank systems, both underground and aboveground, constructed of any material, and storing nearly any product—gasoline, diesel, residential and commercial heating oils, aviation and jet fuel, biofuels, and others—may be affected.

Today's fuels are more susceptible to moisture separation and accumulation. Also, removing lead from gasoline and sulfur from diesel has had the side effect of allowing microbial growth to occur more readily, uninhibited by lead and sulfur.


Ethanol and biodiesel are important in today's fueling network. However, both are "hygroscopic," meaning they attract water. That's why tank owners and operators must be even more diligent in monitoring for and removing water from fuels and storage and dispensing systems.

For all these reasons, it's more important than ever to conduct regular inspection and maintenance of your entire AST fuel storage system.

Get FREE guidance



STI's document R111, Recommended Practice for Storage Tank Maintenance, is available for free download at: www.stispfa.org



Reduce business risk Protect your fuel product

- Inspect your storage tank system frequently.
- Check for water with automatic or manual tank gauging.
- Investigate the source of any water found. Review the resource materials listed in this brochure.
- Remove and properly dispose of any water found or take other corrective action, in accordance with industry recommended practices.
- Consider alternative methods to control water in fuel and storage system, such as biocides, fuel "polishers," or corrosion inhibitors.
- Audit the fuel or product delivery process and the water content.
- Use water-sensitive filters and watch for slowed-down fueling or dispensing.
- Employ a qualified professional to periodically examine the inside of the tank.
- Remove water and sludge and periodically clean the tank, in accordance with industry-recommended practices.